



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 1
5 Post Office Square, Suite 100
Boston, MA 02109-3912

CERTIFIED MAIL – RETURN RECEIPT REQUESTED
AUG 7 – 2018

Mr. Peter Newman, Chairman
Mr. Peter Savlen, Commissioner
Mr. Daniel Lavoie, Commissioner
PO Box 265
Warner Village Water District
Warner, NH 03278

Re: NPDES Permit No. NH0100498
Administrative Order on Consent Docket No. CWA-AO-R01-FY17-15
New Schedule Milestones

Dear Commissioners:

EPA and the New Hampshire Department of Environmental Services ("NHDES") have reviewed the Warner Village Water District's ("District's") July 31, 2018 progress report and the proposed project schedules contained within. Pursuant to paragraphs IV.1.a., IV.1.c and IV.1.d. of the Administrative Order on Consent Docket no. CWA-AO-R01-FY17-15 ("AOC"), by this letter, the following schedule milestones shall be incorporated and enforceable under the AOC:

- By August 31, 2018, fully implement the District's Phosphorus Optimization Plan to achieve full compliance with the seasonal (i.e. April 1 through October 31) 1.75 pounds per day monthly average effluent limit for Total Phosphorus contained in NPDES Permit No. NH0100498;
- Beginning on October 1, 2018, the interim effluent limit for Total Phosphorus is withdrawn and the seasonal (i.e. April 1 through October 31) 1.75 pounds per day monthly average effluent limit for Total Phosphorus contained in NPDES Permit No. NH0100498 is in full effect;
- By September 1, 2018, obtain any necessary State permits and, by September 28, 2018, complete all necessary tests to determine the feasibility of utilizing a groundwater discharge system to achieve compliance as soon as practicable and by no later than September 28, 2021;

- By October 15, 2018, submit an engineering letter report on the feasibility of utilizing a groundwater discharge system to achieve compliance as soon as practicable and propose a schedule for completing treatment system design and construction, and for achieving compliance by no later than September 28, 2021.

Please contact Joy Hilton of my staff regarding any questions that you may have regarding the terms and conditions of the Order. She can be reached at (617) 918-1877.

Sincerely,



Timothy Conway, Acting Director
Office of Environmental Stewardship

cc: Ray Martin, District Administrator (via email)
Teresa Ptak, NHDES (via email)
Mitch Locker, NHDES (via email)
Diane Boisclair, EPA (via email)